

## Recommended initial frequency of inspection and testing

Jan-21

Environment	Type	Class I		Class II	
		FVI	FVI & test	FVI	FVI & test
Construction sites	Stationary	1 month	3 months	1 month	3 months
	IT	N/A	N/A	N/A	N/A
	Moveable	1 month	3 months	1 month	3 months
	Portable	1 month	3 months	1 month	3 months
	Handheld	1 month	3 months	1 month	3 months
Industrial & Commercial Kitchens	Stationary	none	24 months	none	24 months
	IT	none	24 months	none	24 months
	Fixed	12 months	24 months	12 months	48 months
	Moveable	6 months	12 months	6 months	24 months
	Portable	6 months	12 months	6 months	12 months
	Handheld	6 months	12 months	6 months	12 months
Equipment used by the public	Stationary	monthly	12 months	12 months	24 months
	IT	monthly	12 months	12 months	24 months
	Fixed	12 months	36 months	12 months	24 months
	Moveable	weekly	6 months	6 months	12 months
	Portable	weekly	6 months	6 months	12 months
	Handheld	weekly	6 months	6 months	12 months
Schools	Stationary	none	12 months	12 months	48 months
	IT	none	12 months	12 months	48 months
	Fixed	12 months	36 months	12 months	48 months
	Moveable	6 months	12 months	12 months	48 months
	Portable	6 months	12 months	12 months	48 months
	Handheld	6 months	12 months	12 months	48 months
Offices, Hotels & Shops	Stationary	24 months	60 months	24 months	none
	IT	24 months	60 months	24 months	none
	Fixed	24 months	48 months	24 months	none
	Moveable	12 months	24 months	24 months	none
	Portable	12 months	24 months	24 months	none
	Handheld	12 months	24 months	12 months	none

These are guidelines to assist with the risk assesment process

User checks are recommended everytime the appliance is used